

Calculations Report

Project data

Client: X Season: Lato +30

Project Number: 00-2020 Calculations author: BK

Object: Elektrownia Date: 03-08-2009 Today

Venting zone: Hala Maszynowni

Mechanical ventilation

Amount of inlet and exhaust vents: 2

1 2

Name: Wywiew mechaniczny

Height of hole middle o.grond h[m]: 22 Air inlet temperature T [°C]: 37

Volume stream V' [m³/h]: -45000

Natural Ventilation

Number of ventilation openings: 4 Calculate results Generate report

1 2 3 4

Name: Wywietrzaki na dachu

Height of hole middle o.grond h[m]: 37,8 Coefficient of the flow Cv [-]: 0,40

Area opening Ag [m²]: 211,0 Coefficient of wind resis. Cw [-]: 0

Calculation results

Name	Designation	Value	Unit
Surface area of shop	A	3864,00	[m²]
Volume of shop	VR	141036	[m³]
Net volume of shop	VRN	70518	[m³]
Total thermal flow	Q'g	2670,00	[kW]
Specific internal heat of net shop volume	Q'i	37,86	[W/m³]
Exhaust air temperature	t out	43,6	[°C]
Change in exhaust temperature	Δt out	13,6	[K]
Displacement of outdoor air (per hour)	LW	6,45	[1/h]
Height of neutral zone from ground	NZ	32,03	[m]
For incoming air (geometric)	Ag in	120,64	[m²]
For incoming air (aerodynamic)	Aw in	36,19	[m²]
For outgoing air (geometric)	Ag out	211,00	[m²]
For outgoing air (aerodynamic)	Aw out	84,40	[m²]
Incoming natural volumetric flow of air	V in	454678	[m³/h]
Outgoing natural volumetric flow of air	V out	608639	[m³/h]
Incoming mechanical volumetric flow of air	V' in	173400	[m³/h]
Outgoing mechanical volumetric flow of air	V' out	45000	[m³/h]

Input data

Name	Designation	Value	Unit
Room length	a	92	[m]
Room width	b	42	[m]
Mean room height	h av	36,5	[m]
Maximum building height (roof ridge)	h	37	[m]
Degree of obstruction	VB	0,5	[-]
Mean wind speed	U ^{av}	0	[m/s]
External air temperature	te	30	[°C]
Thermal load from Q'-process	Q'	2630	[kW]
Degree of room loading	μT	0,60	[-]
Thermal loads from outside	Q'A	40	[kW]
Exhaust air temperature	t ab,0	45	[°C]
Accuracy of iteration	k	0,1	[-]